

OWENSBORO MUNICIPAL UTILITIES

BID # 17-07-049

OMU DELIVERY DEPARTMENT WAREHOUSE EXTENSION

ADDENDUM # 2

July 11, 2017

Each bidder shall note this revision to the contract documents and incorporate this revision in his proposal. Each bidder shall sign the addendum acknowledgement below, and attach the signed addendum to their submitted bid proposal.

- 1. Weight capacity PSI per square foot shall be 150# instead of 125#**
- 2. Bidder to submit general drawing with bid pricing**
- 3. Bar grade flooring is required**
- 4. Past warehouse building drawing reflects a 6" thick concrete base floor**

ACKNOWLEDGEMENT

The undersigned bidder hereby certifies that the revision set forth in this addendum has been incorporated in this bid and is a part of the contract documents.

BY _____

COMPANY _____

DATE _____