

OWENSBORO MUNICIPAL UTILITIES

BID # 17-07-044

**OMU FGD "A" ABSORBER INLET DAMPER SYSTEM
FRAME REPLACEMENT**

ADDENDUM # 1

July 24, 2017

Each bidder shall note this revision to the contract documents and incorporate this revision in his proposal. Each bidder shall sign the addendum acknowledgement below, and attach the signed addendum to their submitted bid proposal.

**THIS ADDENDUM IS TO REFLECT THE BID OPENING DATE
CHANGED TO JULY 31, 2017 @ 2:00 P.M. ALONG WITH A
NEW AND DIFFERENT DESIGN THAT SUPERSEDES
PREVIOUS DESIGN AND DRAWINGS.**

Please find attached, three drawings defining the temporary support steel for the suspension of the ambient frame. This design supersedes design and drawings supplied in the original invitation to bid. OMU will provide the structural steel. This design provides for 52K lb + 25% for three suspension points, using that value but providing for four suspension points. In addition, due to the short lift, the drawing shows turnbuckles as the mode of hoist. Any questions regarding the above should be directed to Technical Services, Daryl Chinn.

ACKNOWLEDGEMENT

The undersigned bidder hereby certifies that the revision set forth in this addendum has been incorporated in this bid and is a part of the contract documents.

BY _____

COMPANY _____

DATE _____