

OWENSBORO MUNICIPAL UTILITIES

BID # 16-04-029

**OMU CUSTOMER SERVICE CENTER GEOTHERMAL COOLING SYSTEM IMPROVEMENTS
PROJECT**

ADDENDUM # 2

April 13, 2016

Each bidder shall note this revision to the contract documents and incorporate this revision in his proposal. Each bidder shall sign the addendum acknowledgement below, and attach the signed addendum to their submitted bid proposal.

THIS ADDENDUM CONSISTS OF THE FOLLOWING ATTACHED PAGE.

ACKNOWLEDGEMENT

The undersigned bidder hereby certifies that the revision set forth in this addendum has been incorporated in this bid and is a part of the contract documents.

BY _____

COMPANY _____

DATE _____

ADDENDUM NO. 2

Revision to Addendum #1 issued earlier

Engineer:

Nami Nahid, PE
Stewart Richey Engineering
(270) 842-5184

Owner:

Owensboro Municipal Utilities (Customer Service Center)
2070 Tamarack Road, Owensboro, KY 42301

Mechanical Controls:

1. Existing building controls is Trane, however the owner may replace the entire control system in future projects. With that in mind, the control for the geothermal cooling shall be a stand-alone operation. Engage a control contractor to provide a main controller tied to an on-line access. The controller shall be BACnet for future open protocol with any other control provider. I recommend ABC controls for this work.