

Local people.



Local service.

February 25, 2021

**Bid Addendum #1
SUB I 69kV TRANSMISSION CONSTRUCTION
BID # 21-03-009**

Contractor shall remove approximately 260' of 397 ACSR in the rear of the substation. The conductor runs from the substation structure to 3-pole dead end structure in the rear of the property with an intermediate pole at 126 feet from the structure. Conductor will be de-energized but conductors on the opposite side of the pole may remain energized depending on when the work occurs and the loading on the station at the time.

Please include a sign copy of this Bid Addendum in your bid package.

**OWENSBORO MUNICIPAL UTILITIES
ATTN: DEREK PRICE
BID # 21-03-009
1531 EAST 4TH STREET
OWENSBORO, KY 42303**

Please sign and attach to your bid:

Company Name: _____

Representative: _____