

NOTIFICATION OF CONSTITUENTS IN GROUNDWATER EXCEEDING GROUNDWATER PROTECTION STANDARDS

Owensboro Municipal Utilities – Elmer Smith Station

**Owensboro, Daviess County, Kentucky
U.S. EPA Coal Combustion Residuals Rule**

June 8, 2021

NOTICE

Pursuant to 40 CFR §257.95(g) and 40 CFR §257.107(h)(6), constituents have been detected at statistically significant levels (SSLs) exceeding the groundwater protection standards (GPWS) in the groundwater monitoring network for the Coal Ash Ponds, a coal combustion residuals impoundment located at the Elmer Smith Station in Daviess County, Owensboro, Kentucky. The following constituents were detected in the listed groundwater monitoring wells at SSLs:

- Molybdenum in MW-5 and MW-6 (since April 2018).
- Selenium in MW-6 (December 2020).

This notification fulfills the requirement outlined in 40 CFR §257.105 (h)(8) and has been placed in the operating record.



Prepared by:

